

Work at Height Safety Compliance

Checklist

NO	CHECKLIST	YES	NO	COMMENTS
1.	Openings through which a person may fall are covered or guarded with effective barriers.			
2.	Handrails and lower rails are installed on open sides of staircases.			
3.	Working platforms are certified, sound, and capable of supporting the worker's weight.			
4.	Safe means of access and egress are provided at elevated areas.			
5.	Workers are equipped with personal fall arrest systems, with secured anchorages.			
6.	Workers are equipped with personal fall arrest systems, with secured anchorages.			

7.	Anchor points are tested and certified for use with fall arrest systems.			
8.	Good housekeeping is maintained to eliminate tripping hazards.			
9.	Workers receive training on the proper use of fall protection equipment.			
10.	Weather conditions are assessed before work begins to avoid hazards such as wind or rain.			
11.	Equipment, including ladders, scaffolds, and MEWPs, is inspected before use.			
12.	Signs or barriers are installed to prevent unauthorized access to elevated areas.			
13.	Tools and materials are secured to prevent them from falling.			

14. Emergency evacuation procedures are in place and communicated to workers.

15. A competent supervisor is appointed to oversee all work at height activities.

Further Comments & Action

Large empty area for further comments and action.